



## PLAN SUBMITTAL CHECKLIST

### **FLAMMABLE & COMBUSTIBLE LIQUID - ABOVE GROUND STORAGE TANKS**

1. Has the Flammable & Combustible liquid tank and associated systems and materials been submitted to the fire jurisdiction having authority for permit and approval?

**Yes** Submit evidence of application and approval by the fire jurisdiction having authority. Any work involving structural or electrical work must be also submitted by a registered design professional, along with the applicable review fees.

**No** Submit evidence of compliance to all applicable sections of the OBC, including section 414.6, the Ohio Fire Code, section 1301:7-7-57 and NFPA 30, 30A & 70. Any work involving Flammable & Combustible materials, structural or electrical work must be submitted by a registered design professional, along with the applicable review fees.

The following additional information shall be provided if answered "No" to Item #1, above.

- Provide tank manufacturer's plans, cut sheets and specifications.
- Provide Flammable & Combustible Material Safety Data Sheets and material quantities.
- Indicate Power (NFPA 70) / Fuel (NFPA 30) shut-offs to appliances/equipment (shut-off no less than 20' and not more than 100' from dispensing device).
- Show details of grounding systems.

2. Does the scope of work involve the installation and/or modification of a new Structural Support and/or electrical system?

\_\_\_ No (If no, please make note on plans to this effect).

\_\_\_ Yes (If yes, plans and specifications of this work must be provided from a registered design professional, along with the applicable review fees).

3. Indicate tank(s) and site structures/building locations with dimensions. Also, locate property lines, fences, containment, etc.

Revised 04/02/2019